# Acorn Chandeliers



# 2413211 Traditional Trim





RIP1730 Antique Brass

RIP1734 Antique Brass


24"


#### **Specifications:**


- Trim rings are spun from .063" thick base material (brass or aluminum) or 18 gauge steel (plated or painted).
- Chassis is formed from 18 gauge cold-rolled steel.
- 3/8 IP (.688" dia.) stem with a 1/2 IP (.875" dia.) sleeve.
- Formed acrylic bowl with a minimum wall thickness of .118".
   Opal finish is standard.
- Integral fluorescent ballasts are HPF electronic with low harmonic distortion.
- H.I.D. ballasts are magnetic HX-HPF for 150 watt and below.
   Magnetic CWA-HPF ballasts are used for over 150 watts. H.I.D. ballasts are remote mounted.
- Ballasts are thermally protected.
- Fluorescent ballasts have a Class "A" and H.I.D. a Class "B" sound rating.
- Inner steel support bracket attaches to 4" octagonal box.
- 45° swivel canopy is standard and meets all earthquake related codes.
- UL listed (US and Canada) for damp locations. (Not recommended for exterior use.)


Design modification rights reserved

# Traditional Trim 2-Bowl













# Traditional Trim 4-Bowl










For further detail on options, see Technical Notes on page 264.



Sample model number: RIP1720 - 2F39/1F39 - 120 - BAL - HP02

Select Select **Select any Lamping Select Options** Style Voltage **Select Finish** (indirect/bowl illumination) Lamping Detail (indirect - bowl illumination) Optical Pkg. Photometry 1M100PSC/1F40 100W ED17 PULSE START CERAMIC MH - 40W CIRC T5 A E402-17 120 Painted. (Include Paint OAH Pendant length other than RIP1720 Number.) standard. (Provide fixture 1M150PSC/1F40 150W ED17 PULSE START CERAMIC MH - 40W CIRC T5 E402-17 277 **RIP1724** 2-B0W height in inches.) PBR Polished solid brass 1M250/1F40 250W BT28 MH - 40W CIRC T5 E402-17 **RIP1728** F Fuse option (M and F) **BBR** Brushed solid brass 1M250PS/1F40 250W ED28 PULSE START MH - 40W CIRC T5 E402-17 RIP1732 RPI Remote ballast support tray ABR Antique solid brass 1M350PS/1F40 350W ED28 PULSE START MH - 40W CIRC T5 E402-17 Α EMI1 Emergency ballast(s) integral **CPBR** Chrome plated 1M400/1F40 400W BT28 MH - 40W CIRC T5 Α E402-17 RIP1740 polished brass **EMR** Emergency ballast(s) remote 400W ED28 PULSE START MH - 40W CIRC T5 1M400PS/1F40 Α E402-17 4-B0WL RIP1744 BAL Brushed aluminum SBA Sandblasted acrylic 1N300 300W PS30 INC В **RIP1748** ABST Antique brass over steel SAV Traditional ballast canopy 2T250 (2) 250W T10 QTZ C E433-75R RIP1752 **BBST** Brushed brass over steel SS Separate switching 2F39/1F391 (2) FT39W/2G11 - FT39W/2G11 D E433-71 Polished chrome over steel HP01 Silver hand-painted acrylic 2F39DM/1F391 (2) FT39W/2G11 - FT39W/2G11 D E433-71 PBST Polished brass over steel HP02 Beige hand-painted acrylic 4F32/1F22 (4) CFTR32W/GX24q - 22W CIRC T5 Ε E402-20 See Finish Selection Guide, HP03 Amber hand-painted acrylic 4F42/1F22 (4) CFTR42W/GX24q - 22W CIRC T5 pages 268-269. Ε E402-20 FIN Finial option **DM** = Dimming ballast(s) provided If Photometry is not available, consult factory for further details. <sup>1</sup>Denotes lamping options available with **EMI** Traditional The lamping is per bowl of the Chandelier.

### OPTICAL PACKAGES




32"


#### **Specifications:**


- Trim rings are spun from .063" thick base material (brass or aluminum) or 18 gauge steel (plated or painted).
- Chassis is formed from 18 gauge cold-rolled steel.
- 3/8 IP (.688" dia.) stem with a 1/2 IP (.875" dia.) sleeve.
- Formed acrylic bowl with a minimum wall thickness of .118".
   Opal finish is standard.
- Integral fluorescent ballasts are HPF electronic with low harmonic distortion.
- H.I.D. ballasts are magnetic HX-HPF for 150 watt and below.
   Magnetic CWA-HPF ballasts are used for over 150 watts. H.I.D. ballasts are remote mounted.
- Ballasts are thermally protected.
- Fluorescent ballasts have a Class "A" and H.I.D. a Class "B" sound rating.
- Inner steel support bracket attaches to 4" octagonal box.
- 45° swivel canopy is standard and meets all earthquake related codes.
- UL listed (US and Canada) for damp locations. (Not recommended for exterior use.)


Design modification rights reserved.

# Traditional Trim 2-Bowl













# Traditional Trim 4-Bowl













A, G, L Symmetrics Symmetrical Direct

# Sample model number: RIP1722 - 4F40/2F40 - 120 - BAL - HP02

ſ	Select Style	Select any Lamping (indirect/bowl illumination)				Select Voltage		Select Finish		Select Options
			Lamping Detail (indirect - bowl illumination)	Optical Pkg.	Photometry			•		▼
4-B0WL 2-B0WL	RIP1722 RIP1726 RIP1730 RIP1734	1M100PSC/1F40	100W ED17 PULSE START CERAMIC MH - 40W CIRC T5	Α	E402-17	120 277	PT	Painted. (Include Paint Number.)	OAH	standard. (Provide fixture height in inches.)
		1M150PSC/1F40	150W ED17 PULSE START CERAMIC MH - 40W CIRC T5	А	E402-17					
		1M250/1F40	250W BT28 MH - 40W CIRC T5	А	E402-17		PBR	Polished solid brass		
		1M250PS/1F40	250W ED28 PULSE START MH - 40W CIRC T5	A	E402-17		BBR	Brushed solid brass		Fuse option (M and F)
		1M350PS/1F40	350W ED28 PULSE START MH - 40W CIRC T5		E402-17		ABR	Antique solid brass	RPI	Remote ballast support tray
		1M400/1F40	400W BT28 MH - 40W CIRC T5		E402-17		CPBR	Chrome plated polished brass	EMI <sup>1</sup>	Emergency ballast(s) integral
									EMR	Emergency ballast(s) remote
	RIP1746	1M400PS/1F40	400W BT28 PULSE START MH - 40W CIRC T5		E402-17		BAL	Brushed aluminum	SBA	Sandblasted acrylic
	RIP1750	3N150	(3) 150W A21 INC	В	NA		ABST	Antique brass over steel	SAV	Traditional ballast canopy
	RIP1754	3T250	(3) 250W T10 QTZ	В	NA		BBST	Brushed brass over steel	SS	Separate switching
L		4F40/2F40 <sup>1</sup>	(4) FT40W/2G11 - (2) FT40W/2G11	С	E433-72		CPST	Polished chrome over steel	HP01	Silver hand-painted acrylic
		4F40DM/2F40 <sup>1</sup>	(4) FT40W/2G11 - (2) FT40W/2G11	C	E433-72		PBST	Polished brass over steel	HP02	Beige hand-painted acrylic
		6F40/1F40 <sup>1</sup>	(6) FT40W/2G11 - 40W CIRC T5	D	E433-87		See Fi	nish Selection Guide.	HP03	Amber hand-painted acrylic
		6F40DM1F40 <sup>1</sup>	(6) FT40W/2G11 - 40W CIRC T5	D	E433-87		pages 268-269.		FIN	' '
		6F55/1F40 <sup>1</sup>	(6) FT55W/2G11 - 40W CIRC T5	D	E433-87				FIN	Finial option
		2F40/4F40	(2) FT40W/2G11 - (4) FT40W/2G11	Е	ITL3691A					
		DM = Dimming ballast(s)  1Denotes lamping options The lamping is per bowl of	available with <b>EMI</b> consult factory		ot available, ther details.					Traditional ther detail on options, chnical Notes on page 264.

# OPTICAL PACKAGES

