



SGS U.S. Testing Company Inc.

1341 North 108th East Avenue • Tulsa, OK 74116 • Tel: 918-437-8333 • Fax: 918-437-8487

CLIENT: Dean Enterprises
7900 E. 40th Ave.
Denver, CO 80207

Attn: Patrick Dean

Test Report No: 166429-8R	Date: May 6, 2002
----------------------------------	--------------------------

SUBJECT: Resistance to Mold Growth of Surface Coatings.

REFERENCE: Letter

SAMPLE ID: One sample of DECO 20 Seal was received from the client on 3/11/02. The samples were received in good condition. The sample was applied to concrete for testing purposes.

TEST REQUESTED: The samples were tested in accordance with ASTM D 3273-94. The samples were placed in an environmental chamber at 90°F and 90% R.H. and suspended over potting soil that was inoculated with the following fungus:

1. Aureobasidium Pulluans
2. Aspergillus Niger
3. Penicillium

The samples were exposed to this environment for 4 weeks. No revisions to this report will be allowed after 90 days of the report date.

TEST DATE: 3/23/02 – 4/23/02

RESULTS: Results can be found on the following pages.

CONCLUSION: No mold growth was observed on any of the specimens during the 4-week exposure period.

**SIGNED FOR AND ON BEHALF OF
SGS U.S. TESTING COMPANY INC.**

Jeff Simmons

bk Dept. Manager/Product Evaluation

Dale E. Holloway
Tulsa Branch Director

Page 1 of 2

This report is issued by SGS U.S. Testing Company Inc. under its General Conditions for Testing Services, as printed on reverse side. SGS U.S. Testing's responsibility under this report is limited to proven negligence and will in no case be more than the amount of the testing fees. Except by special arrangement, samples are not retained by SGS U.S. Testing for more than 30 days. The results shown on this test report refer only to the sample(s) tested unless otherwise stated, under the conditions agreed upon. Anyone relying on this report should understand all of the details of the engagement. Neither the name, seals, marks nor insignia of SGS U.S. Testing may be used in any advertising or promotional materials without the prior written approval of SGS U.S. Testing. The test report cannot be reproduced, except in full, without prior written permission of SGS U.S. Testing Company Inc.

Member of the SGS Group (Société Générale de Surveillance)

