

Flame Certificate
Skyline by Kvadrat
283722

maharam

Skyline by Kvadrat was tested and met the following flammability requirements:
Upholstered Walls: ASTM E 84 Unadhered flame 5, smoke 60
Windows: NFPA 701

Contact clientservices@maharam.com with any questions.