

Flame Certificate

Tek-Wall Brace

399629

maharam

Tek-Wall Brace was tested and met the following flammability requirements:

Upholstered Walls: ASTM E 84 Unadhered flame: 20, smoke: 190

Walls: ASTM E 84 Adhered flame: 10, smoke: 60

Contact clientservices@maharam.com with any questions.