

Flame Certificate
Tek-Wall Rhombus
399641

maharam

Tek-Wall Rhombus was tested and met the following flammability requirements:
Walls: ASTM E 84 Adhered flame: 10, smoke: 15

Contact clientservices@maharam.com with any questions.