# Fail-Safe

#### **DESCRIPTION**

The VRM combines a low-profile, surface modular design with the latest in energy-efficient technology. The dihedral recessed top design allows for cooler fixture operation. Other features include a die-formed housing, surface or stem mounting (single or continuous row), full seam-welded corners and a broad selection of attractive door frames. The durable, versatile VRM is perfect for use in commercial spaces, schools, hospitals, correctional or industrial facilities and high volume public access areas.

Catalog #	Туре
Project	
Comments	Date

#### SPECIFICATION FEATURES

#### Construction

Housing is die-formed, codegauge, prime cold-rolled steel. Smooth sides permit flush joint for continuous-row mounting. Dihedral recessed top design ensures cooler ballast operation. Die-formed captive lampholder bracket fully encloses wiring permitting easy lampholder replacement. Ballast covers easily removed without tools.

#### Finish

Painted after fabrication.
Electrostatically-applied baked white polyester powder enamel finish. Multistage cleaning cycle, iron phosphate coating with rust inhibitor. Conveyorized application and baking timing accurately controlled at an elevated temperature.

#### Hinging/Latching

Positive cam action steel latches with baked white enamel finish. Safety lock T-hinges allow hinging and latching either side.

#### Frame/Shielding

Die-formed, heavy-gauge, flat steel door with reinforced mitered corners and baked white enamel finish. Positive light seals. Frame and lens are secured to housing with 4 or 6 T20 stainless steel TORX® screws.

#### Electrical \*

Ballasts are CBM/ETL Class "P" and are positively secured by mounting bolts. Pressure lock lampholders.

#### Labels


UL/cUL listed for damp locations.




## **2VRM**

2x2 Vandal Resistant

> SURFACE Lens Troffer




#### **MOUNTING DATA**





#### DOOR FRAME




#### LAMP CONFIGURATIONS









TORX® is a registered trademark of Camcar Division of Textron Inc.

#### **ENERGY DATA**

Input Watts:

#### EB Ballast & STD Lamps

417 (45), 2U6 (72), 2U6T8 (61) 2U1-5/8 (61), 2BX40 (67) 3U1-5/8 (91), 3BX40 (110)

### ES Ballast & STD Lamps

420 (116), 417 (90) 2U6 (86), 2U6T8 (71) 2U1-5/8 (71), 3U1-5/8 (108)

## STD Ballast & STD Lamps

2BX40 (82), 3BX40 (128)

Luminaire Efficacy Rating **LER** = FL-58

#### Catalog Number: 2VRM-2U6T8ACTF140

Yearly Cost of 1000 lumens, 3000 hrs at .08 KWH = \$4.14


\* Reference the lamp/ballast data in theTechnical Section for specific lamp/ballast requirements.






#### ORDERING INFORMATION

### SAMPLE NUMBER: 2VRM-2U6T8A



#### **PHOTOMETRICS**

### **Candlepower Distribution**



Test No. M-3449

2VRM-2U6-ACTF140

Lamp=F40T12/CW

Lumens=3150

Spacing Criteria

L=1.2 II=1.3

Efficiency=62.5%

## Candlepower

Deg.		- 11
0	1515	1515
5	1506	1513
15	1452	1493
25	1337	1421
35	1141	1266
45	836	988
55	467	547
65	252	267
75	174	187
85	57	57
90	0	0

Typical VCP Percentages

Room Size	Heigh	t Along II	Height	$\perp$	
(in Feet)	8'6"	10'0"	8'6"	10'0"	
20 x 20	65	70	64	69	
30 x 30	58	62	57	61	
30 x 60	50	52	49	52	
60 x 30	61	64	60	63	
60 x 60	51	53	51	53	_

#### Zonal Lumen Summary

Zone	Lumens	%Lamp	% Luminaire
0-30	1196	20.8	33.3
0-40	1952	33.9	54.3
0-60	3115	54.2	86.7
0-90	3595	62.5	100.0
90-180	0	0.0	0.0
0-180	3595	62.5	100.0

#### Coefficient of Utilization

rc		8	0%			70%		50	1%	30%	6	10	)%	0%
rw	70	50	30	10	50	30	10	50	10	50	10	50	10	0
RCR														
0	74	74	74	74	73	73	73	69	69	67	67	64	64	63
1	69	66	64	61	65	62	60	62	59	60	57	57	55	54
2	63	59	55	51	57	54	51	55	50	53	49	51	47	46
3	58	52	47	44	51	47	43	49	43	48	42	46	41	40
4	54	47	42	38	46	41	38	44	37	43	37	42	36	35
5	50	42	37	33	41	37	33	40	33	39	32	38	32	31
6	46	38	33	29	38	33	29	37	29	35	29	35	28	27
7	43	35	30	26	34	29	26	33	26	32	26	32	25	24
8	40	32	27	23	31	27	23	31	23	30	23	29	23	22
9	37	29	24	21	29	24	21	28	21	28	21	27	21	20
10	35	27	22	19	27	22	19	26	19	26	19	25	19	18

rc=Ceiling reflectance, rw=W all reflectance, RCR=Room cavity ratio

CU Data Based on 20% Effective Floor Cavity Reflectance.