DESCRIPTION

FAIL-SAFE®

Designed to meet the toughest requirements in cleanroom and BSL applications. For use in horizontal or non-laminar air flow rooms, the enclosed and gasketed housing and one-piece door protect against infiltration of airborne bacteria. Die-formed edges on the door frame and the hole-free design of the housing prevent air exchange between the fixture and the plenum, allowing for re-lamping without contaminating the area. One piece gaskets are included on lens, for easy replacement, and on the door edge. The CRL is suitable for 9/16", 1" and 1-1/2" T-Grid ceilings. UL/cUL listed for wet locations. IP 65 rated and manufactured in accordance with ISO 14644, NSF and Federal Standard 209E in a certified ISO 9001:2000 facility.

Catalog #	Туре				
Project					
Comments	Date				
Prepared by					

SPECIFICATION FEATURES

Application

The CRL is suitable for use in I.E.S. Class 100, 1,000, 10,000, and 100,000 clean room environments. Applications include clean rooms, Biomedical Safety Labs, food processing/testing centers and pharmaceutical labs.

Fasteners

Flush mounted, stainless steel machine screws and molded washers ensure a proper seal; secured through captive cage nuts in the housing, and evenly spaced to compress gasketing on all sides.

Housing

Die-Formed, 20 ga. CRS with tightly butted, seam welded, sealed end caps. Contains no holes that would allow air passage. Standard white high reflectance polyester powder coat finish. Gloss: 85%; Reflectance: 93%; Hardness: 2H; Salt Spray: 500 Hours.

Hinge

Two braided, stainless steel cables on side of door provide hinging.

One-piece, 20 ga. door with baked white polyester powder coat. Fully gasketed, outside door with dieformed edges eliminates seams which could entrap microscopic contaminants. Other doors also available.

Gasket

White, closed cell one-piece silicone gasketing is standard around perimeter of lens, and around perimeter of door. Additional fixture-to-ceiling gasketing is available.

Access

A gasketed access plate on top of the housing with two flattened, 7/8" diameter for 1/2" trade size K.O. allows connection of vapor tight

conduit fitting. Optional aboveceiling, top access door for luminaire maintenance is available.

Lens is clear, extruded with prisms positioned inside the fixture providing a smooth surface on the outside for easy cleaning.

Lamps

T5, T8, Biaxial.

Lens Retention

Unique, one-piece Particulock™ lens retention system utilizes continuous, media clampdowns to sandwich gasketing and integrate lens and door frame for equalized pressure on the lens.

Ballast

Standard Class P, CBM/RTL ballast.

UL/cUL listed, standard wet label, NSF.



CRL

2x2 Cleanroom

RECESSED GRID Inset Flat Door

IP65 Rated





ENERGY DATA

Input Watts:

STD Ballasts & STD Lamps

(2) 40W Biaxial Fluorescents: 82W (3) 40W Biaxial Fluorescents: 127W

T5 ES Ballast & STD Lamps


(2) 24WT5 Fluorescents: 52W (3) 24WT5 Fluorescents: 78W (2) 54WT5 Fluorescents: 106W (3) 54WT5 Fluorescents: 160W


T8 FS Ballast & STD Lamps

(2) 17WT8 Fluorescents: 36W (3) 17WT8 Fluorescents: 56W (2) 32WT8 Fluorescents: 71W (3) 32WT8 Fluorescents: 108W (2) 40W U-Lamps: 86W

Electronic Ballast Data


Consult Cooper Lighting Representative






DOOR FRAME

Grid Type= One Piece Inset Door, One Piece Gasket, One Piece Lens Retention Device



Overall Sizes							
Housing Type A (in) B (in)							
2' x 4'	48"	23-11/16"					
2' x 2'	24"	23-11/16"					

PHOTOMETRICS



CRL-24-632 Electronic Ballast F32T8 Lamps 2850 Lumens Spacing criterion: (II) 1.2 x mounting height, (\bot) 1.3 x mounting height Efficiency 71.5% Test Report: LTL15830

Coefficients of Utilization

Effe	ctive	e flo	or cav	ity ref	lecta	nce		20)%								
	80	%			7	0%			50%	•		30%	, D		10%		0%
70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
85	85	85	85	83	83	83	83	79	79	79	76	76	76	73	73	73	72
78	74	71	69	76	73	70	67	70	67	65	67	65	63	64	63	61	60
71	65	60	56	69	63	59	56	61	57	54	59	55	53	56	54	51	50
64	57	51	46	63	56	50	46	54	49	45	52	48	44	50	46	43	42
59	50	44	39	57	49	43	39	48	42	38	46	41	38	44	41	37	36
54	45	39	34	53	44	38	34	43	37	33	41	37	33	40	36	32	31
50	40	34	30	49	40	34	29	39	33	29	37	32	29	36	32	29	27
46	37	30	26	45	36	30	26	35	30	26	34	29	26	33	29	25	24
43	34	27	23	42	33	27	23	32	27	23	31	26	23	30	26	23	21
40	31	25	21	39	30	25	21	30	24	21	29	24	21	28	24	21	19
38	28	23	19	37	28	23	19	27	22	19	27	22	19	26	22	19	17
	70 85 78 71 64 59 54 50 46 43 40	85 85 78 74 71 65 64 57 59 50 40 46 37 43 34 40 31	80% 70 50 30 85 85 85 78 74 71 61 65 60 64 57 51 59 40 34 50 40 34 40 37 30 40 34 27 40 31 25	80 % 70 50 30 10 85 85 85 85 78 74 71 69 71 65 60 56 64 57 51 46 59 50 44 39 34 50 40 34 30 46 37 30 26 43 34 27 23 40 31 25 21	80 % 70 80 85 85 85 83 83 84 86 86 86 86 86 86 86 86 86 86 86 86 86	Name	70 50 30 10 70 50 30 30 30 30 30 30 3	Name	No. No.	Note	No	No. No.	Note	Note	80% 70% 50% 30% 30% 50 30 10 50 30 10 50 30 10 50 30 10 50 30 10 50 50 30 10 50 50 50 50 50 50 50 50 50 50 50 50 50 80 83 83 83 83 79 79 79 79 76 76 76 73 73 78 74 71 69 76 73 70 67 65 65 63 64 71 65 60 66 63 59 56 61 57 54 59 55 53 56 64 77 71 46 63 56 50 46 54 49 45 52 48 44 50 59 50 44 38 34 43	Note	Note

Zonal	Lumen	Summary

Lumens	%Lamp	%Fixture		
3368	19.7	27.6		
5479	32.0	44.8		
9631	56.3	78.8		
12224	71.5	100.0		
12224	71.5	100.0		
	3368 5479 9631 12224	3368 19.7 5479 32.0 9631 56.3 12224 71.5		

Luminance Data

Angle in Deg	Average 0-Deg cd/sm	Average 45-Deg cd/sm	Average 90-Deg cd/sm
45	6073	6646	6827
55	8097	9117	9433
65	12986	14906	15661
75	25991	29891	33178
85	64751	77019	98658

Candela

Angle	Along II	45°	Across ⊥
0	4433	4433	4433
5	4402	4401	4409
10	4299	4318	4339
15	4137	4187	4232
20	3948	4034	4096
25	3724	3856	3927
30	3475	3644	3722
35	3206	3403	3488
40	2916	3140	3228
45	2618	2865	2943
50	2315	2570	2649
55	2002	2254	2333
60	1684	1916	1996
65	1357	1558	1637
70	1025	1183	1266
75	703	808	897
80	401	463	547
85	153	182	233
90	0	1	10

ORDERING INFORMATION

SAMPLE NUMBER: CRL-24-317-277-IK12-EB81-GLR Door /Finish Options **Product Family** Width Lamp Type Voltage Lens Type Ballast CRL 24 CRL=Clean Room Fluorescent **120**=120V IK12=K-12 Prismatic Electronic Ballast (2) Grid Type with Inset Door **277**=277V **UNV**=120-277V Acrylic , 0.125" thick ID12=K-12 Prismatic EB51=(1) Ballast for finish use with T5 Lamp Impact Resistant EB52=(2) Ballast for **24**=24" Acrylic IP12=K-12 Prismatic use with T5 Lamp FR81=(1) Ballast for Polycarbonate Door/Polyester use with T8 Lamp 2' Fixture Length 4' Fixture Length KSH25=Bat Wing EB82=(2) Ballast for T5HO Fluorescent T5 Fluorescent Distribution use with T8 Lamp 224T5=(2) 24W Lamps 93=Prismatic Door/Polyester 228T5=(2) 28W Lamps EBX1=(1) Ballast for 324T5=(3) 24W Lamps 328T5=(3) 28W Lamps Tempered Glass Powder Finish use with Biax Lamp EBX2=(2) Ballast for 424T5=(4) 24W Lamps 428T5=(4) 28W Lamps 624T5=(6) 24W Lamps 628T5=(6) 28W Lamps use with Biax Lamp T5HO Fluorescent 254T5=(2) 54W Lamps T5 Fluorescent 214T5=(2) 14W Lamps

Blank=Standard, CRS with baked white SSN=Stainless Steel Door/Brushed finish SSP=Stainless Steel Powder Coat Finish ALP=Aluminum Finish

EBP=Emergency Battery Pack GLR=Fuse and Holder RIF=Radio Frequency Interference Filter TAD=Top Access Door **AM**=Antimicrobial

Options

Housing Options SHN=Stainless Steel, Brushed Finish SHP=Stainless Steel, Polyester Powder Finish ALH=Aluminum, Polyester Powder Finish GSK=Gasket Applied

to Housing Lip to Seal Against Grid

632=(6) 32W Lamps

354T5=(3) 54W Lamps

454T5=(4) 54W Lamps **654T5**=(6) 54W Lamps

232=(2) 32W Lamps

332=(3) 32W Lamps

432=(4) 32W Lamps

T8 Fluorescent

For additional options please consult Cooper Lighting Representative. Specifications and Dimensions are subject to change without notice. Electronic ballast may cause interference with other electronic devices. If interference occurs, move the device away from the product or plug/connect into a different circuit/outlet.

⁽¹⁾The KSH25 provides improved visual performance and wide angle distribution. This lens has an integral prism pattern designed so that prisms face the lamp cavity and still supply superior photometrics. ⁽²⁾For specific electronic ballast, specify brand and catalog number.



314T5=(3) 14W Lamps

414T5=(4) 14W Lamps

614T5=(6) 14W Lamps

T8 Fluorescent 217=(2) 17W Lamps

317=(3) 17W Lamps

417=(4) 17W Lamps

617=(6) 17W Lamps

2U 1 5/8=(2) 31WT8 Lamps

3U 1 5/8=(3) 31WT8 Lamps 2U6T8=(2) 32WT8 Lamps **Biaxial Fluorescent**

240BX=(2) 40W Lamps 340BX=(3) 40W Lamps

U Lamp