Lumière

DESCRIPTION

Monaco 3000 series is a small scale, versatile, LED, HID or incandescent inground illuminator for use with T4.5, T6, T3.5; PAR20 and PAR30 metal halide lamps or LED. The adjustable versions, 3000A, 3001A and 3002A provide up to 25° tilt and 360° rotation of the lamp beam allowing for precision aiming. The non-adjustable versions, 3000N, 3001N and 3002N provide a fixed uplight. The Monaco 3000 is ideal for uplighting building facades, trees, columns, and other interesting site features.

Catalog #	Туре
Project	
Comments	Date
Prepared by	

SPECIFICATION FEATURES

Recessed housing is constructed from corrosion-proof, injection molded polyphenylene sulfide (PPS). Trim ring is constructed from corrosion-resistant brass or stainless steel.

Finish

Painted trim rings are constructed from solid brass with a polyester powdercoat paint finish. A variety of standard colors is available. Machined natural brass or stainless steel trim rings are unpainted and available in either round or square forms. Brass will patina naturally over time.

Domed 1/2" thick tempered glass lens, factory sealed with high temperature gasket to prevent water intrusion. Suitable for driveover applications to 5000 lbs.

Hardware

Stainless steel hardware is standard to provide maximum corrosion-resistance. Outer trim ring includes captive fasteners.

Electrical

LED fixtures include an integral. universal input driver (120V -277V).

LED Light Engine

LED light engine is included and comes equipped with (7) 3-watt white LEDs. Factory configurable optics allow for four optical distributions. High CRI of 85 with excellent color consistency of +/-50K color temperature.

Dimming

The LED light engine is dimmable to 15% with electronic low voltage equipment (ELV dimmers need a neutral connection in the wall box).

Warranty

Lumiere warrants it's fixtures against defects in materials & workmanship for three (3) years. Driver carries the original manufacturer's warranty.

Recessed Housing

Recessed housing is provided with two 3/4 inch NPS threaded conduit entries. The recessed housing is available to ship in advance of complete fixture for rough-in purposes. Specify option -LBB and order recessed housing and accompanying components from below:

Recessed housing: 3000-BBR 3000-BBS


Recessed housing with fusing: 3000-BBR-FUS 3000-BBS-FUS



MONACO

3002A LED

APPLICATIONS: ADJUSTABLE INGROUND



CERTIFICATION DATA

UL and cUL Wet Location Listed LM79 / LM80 Compliant **ROHS** Compliant IP67 Ingressed Protection Rated

TECHNICAL DATA

18 Watt Max. LED 40°C Maximum Temperature Rating

ORDERING INFORMATION

Sample Number: 3002A-RD-18LED3000-MFL-CLR-UNV-BZ

Series	Trim	Source	Distribution	Top Glass	Voltage	Finish ¹	Other
3002A=Monaco 3002	RD=Round	18LED3000 =18W LED,	SP=9° Spot	CLR=ClearTop Glass	UNV=120-277V	Painted	LBB=Less Back Box
LED Adjustable Aiming	SQ=Square	3000K, 85 CRI	NFL=15° Narrow Flood	DIF =DiffuseTop Glass	50/60Hz, electronic	BK=Black	FUS=Fusing
		18LED4000 =18W LED,	MFL=25° Medium Flood	NSL=Non-Slip Lens	driver	BZ=Bronze	
		4000K, 85 CRI	WFL=40° Wide Flood			CS=City Silver	
						VE=Verde	
						WT=White	
					Premium Material		
						NSS=Natural Stainless	
						Steel	
						NBR=Natural Brass	



ACCESSORIES

Filters (4.95" Diameter)	Optical Lenses (4.95" Diameter)	Optical Louvers (4.95" Diameter)	Light Control	Electrical
F71-38 = Peach Dichroic F72-38 = Amber Dichroic F73-38 = Green Dichroic F73-38 = Medium Blue F75-38 = Yellow Dichroic F76-38 = Red Dichroic F77-38 = Dark Blue Dichroic F77-38 = Light Blue Dichroic F78-38 = Light Blue Dichroic F78-38 = Neutral Density Dichroic F80-38 = Magenta Dichroic F22-38 = Red Color F33-38 = Blue Color F44-38 = Green Color F55-38 = Yellow Color F66-38 = Mercury Vapor	LSL-38=Linear Spread Lens (elongates standard beam spread) DIF-38=Diffused Lens (provides even illumination) OSL-38=Overall Spread Lens (increases standard beam spread)	LVR-38=45° Hex Cell Louver (reduces glare)	3000-RG=Rock Guard 3000-SG=Straight Glare Shield	3000-FUS=Fusing Package

PHOTOMETRY

3002A-18LED3000-SP				
Test N	0.	P1668	40	
ССТ		3000K		
Lumer	ns	967 Ln	n	
Watts		16.6 W		
LPW		58.3 Lı	n/W	
Beam	Angle	8.9°		
Field A	ngle	17.2°		
СВСР		30118	cd	
CONE OF LIGHT				
0° D				
D	FC	L	W	
10′	301.2	1.4	1.4	
20′	75.3	3	3	
30′	33.5	4.6	4.6	
40′	18.8	6.2	6.2	

3002A-18LED4000-SP

P166844

4000K

1113 Lm

16.7 W

8.9°

17.4°

L

1.4

3

4.6

6

CONE OF LIGHT

34797 cd

Ď

W

1.4

3

4.6

6

66.6 Lm/W

Test No.

Lumens

Watts

LPW

CBCP

D

10'

20'

30'

40′

FC

348

87


38.7

21.7


Beam Angle

Field Angle

CCT



300	3002A-18LED4000-NFL				
Test N	о.	P1668	43		
CCT		4000K			
Lumer	าร	1130 L	m		
Watts		16.6 W	,		
LPW		68.1 L	m/W		
Beam	Angle	14.1°			
Field A	Angle	24.2°			
СВСР		17220 cd			
CONE OF LIGHT					
0° D					
D	FC	L	W		
10′	172.2	2.4	2.4		
20′	43.1	4.8	4.8		
30′	19.1	7.2	7.2		
40′	10.8	9	9		



300	2A-18LE	D4000-l	ИFL	
Test N	0.	P166842		
ССТ		4000K		
Lumer	าร	964 Lm		
Watts		16.6 W	,	
LPW		58.1 L	m/W	
Beam	Angle	21.3°		
Field A	ngle	46.2°		
СВСР		4753 cd		
	CONE O	F LIGHT		
0° D				
D	FC	L	W	
10′	47.5	3.4	3.4	
20′	11.9	7	7	
30′	5.3	10.6	10.6	
40′	3	14.2	14.2	

3002A-18LED3000-WFL				
Test No	0.	P1668	41	
ССТ		3000K		
Lumer	ıs	947 Ln	n	
Watts		16.6 W	'	
LPW		57.0 Lr	n/W	
Beam	Angle	36.2°		
Field A	ngle	53.2°		
СВСР	СВСР		2674 cd	
CONE OF LIGHT				
0°				
D	FC	L	W	
10′	26.7	6	6	
20′	6.7	12	12	
30′	3	18	18	
40′	1.7	23.4	23.4	

Test N	0.	P166845		
ССТ		4000K		
Lumer	าร	1070 Lm		
Watts		16.7 W		
LPW		64.0 Li	m/W	
Beam	Angle	36°		
Field Angle 53.8°				
СВСР		2880 c	d	
CONE OF LIGHT				
0° D				
D	FC	L	W	
10′	28.8	5.8	5.8	
20′	7.2	11.8	11.8	
30′	3.2	17.8	17.8	
40′		_		


3002A-18LED4000-WFL




INSTALLATION NOTES

Caution: To prevent water, dirt and debris from collecting, install fixture to allow runoff. Do not install fixture in areas where water can collect for long periods of time. Appropriate drainage must be provided.

Excavated hole must be approximately 15" in diameter by 20" in depth. Fixture must be installed with a minimum 4" depth of pea gravel or equivalent drainage base. Backfill an additional 8" depth of pea gravel on lower portion of fixture for soil stability. For more detailed installation instructions and warnings consult factory.





Bottom view of recessed housing showing two 3/4 inch NPS conduit entries.

