

F140-2IM-2WL

Joint Width		Movement \pm			
		Horizontal		Vertical	
US	mm	US	mm	US	mm
2"	50	1"	25	-	-

RATED SUBSTRATE MUST BE IN COMPLIANCE WITH UL ASSEMBLY REQUIREMENTS (BY OTHERS)

FINISH: n/a

• **JOINTMASTER®**
EXPANSION JOINT SYSTEMS
A DIVISION OF INPRO®

DATE: 12/20/17

SCALE: 1:2

DOC: CADJM.193/R1

F140 WALL FIRE BARRIER


PROJECT:

CUSTOMER:

LOCATION:

inpro.

For More Information Visit: Inprocorp.com



F140-2IM-3WL

Joint Width		Movement \pm			
		Horizontal		Vertical	
US	mm	US	mm	US	mm
3"	75	1 1/2"	38	-	-

RATED SUBSTRATE MUST BE IN COMPLIANCE WITH UL ASSEMBLY REQUIREMENTS (BY OTHERS)

FINISH: n/a

• **JOINTMASTER®**
EXPANSION JOINT SYSTEMS
A DIVISION OF INPRO®

DATE: 12/20/17

SCALE: 1:2

DOC: CADJM.193/R1

F140 WALL FIRE BARRIER


PROJECT:

CUSTOMER:

LOCATION:

inpro.

For More Information Visit: Inprocorp.com



F140-2IM-4WL

Joint Width		Movement \pm			
		Horizontal		Vertical	
US	mm	US	mm	US	mm
4"	102	2"	52	-	-

RATED SUBSTRATE MUST BE IN COMPLIANCE WITH UL ASSEMBLY REQUIREMENTS (BY OTHERS)

FINISH: n/a

• **JOINTMASTER**
EXPANSION JOINT SYSTEMS
A DIVISION OF INPRO

DATE: 12/20/17

SCALE: 1:2

DOC: CADJM.193/R1

F140 WALL FIRE BARRIER

PROJECT:

CUSTOMER:

LOCATION:

inpro.

For More Information Visit: Inprocorp.com