



COMMERCIAL TESTING COMPANY

Post Office Box 985 *1215 South Hamilton Street *Dalton, Georgia 30722
Telephone (706) 278-3935 *Facsimile (706) 278-3936

Report Number 01-10109.1

Masland Carpets, Inc.
Saraland, Alabama

Test Number 3270-7269-A
October 10, 2001

Flooring Radiant Panel Test

Test Method: The test was conducted in accordance with the ASTM fire test response standard E 648-00, *Critical Radiant Flux of Floor-Covering Systems Using a Radiant Heat Energy Source*. It measures the critical radiant flux at flame-out of horizontally mounted floor-covering systems that duplicate or simulate accepted installation practices. The floor-covering system is exposed to a flaming ignition source in a graded radiant heat energy environment generated by a radiant panel inclined at a 30° angle to the sample. The panel generates a heat distribution along the sample length ranging from a nominal maximum of 1.0 W/cm² to a minimum of 0.1 W/cm². Tests on individual components are of limited value and are not valid for evaluation of floor-covering systems.

Floor Covering:

Identification: 7219 Tansu

Color: 12921 Indigo

Construction: Cut/Uncut Pile

Total Weight: 67.9 oz/yd²

Secondary Backing: Woven Synthetic

Flooring System:

Application: Glue-Down

Subfloor: Simulated Concrete (Reinforced Cement Board)

Adhesive: Henry 356

Test Result:

	#1	#2	#3
Maximum Burn Distance (cm)	32.3	31.9	31.0
Time to Flame Out (min)	56.5	49.4	45.2
Critical Radiant Flux	0.64	0.65	0.67
Average Critical Radiant Flux	0.65 W/cm²		
Standard Deviation	0.0135		

Classification: The floor-covering system tested may be classified as a **Type I** installation based on the NFPA 101 *Life Safety Code*, or a **Class A** as defined by the GSA in Solicitation Number 3FNH-98-F301-B, CP-FSS-1-C (March 1998), 3FNE Technical Requirements Booklet, March 26, 1998. However, care must be exercised in their use as a material may be otherwise classified by the authority having jurisdiction.

Commercial Testing Company

(Authorized Signature)

The ASTM E 648 test conducted by Commercial Testing Company is recognized by the United States Department of Commerce, National Institute of Standards and Technology (NIST), through the National Voluntary Laboratory Accreditation Program (NVLAP) for compliance with Title 15 of the Code of Federal Regulations, Part 285. These criteria encompass the requirements of ISO/IEC Guide 25 and the relevant requirements of ISO 9002 (ANSI/ASQC Q92-1987). This report is provided for the exclusive use of the client to whom it is addressed. It may be used in its entirety to gain product acceptance from duly constituted authorities. The test results presented in this report apply only to the samples tested and are not necessarily indicative of apparent identical or similar materials. Sample selection and identification were provided by the client. A sampling plan, if described in the referenced standard, was not necessarily followed. This report, or the name of Commercial Testing Company, shall not be used under any circumstance in advertising to the general public.

TESTED TO BE SURE®....Since 1974