

## Flame Certificate

Morse

901720

**maharam**

Morse was tested and met the following flammability requirements:

Systems: ASTM E 84 Unadhered flame 5, smoke 105

Upholstered Walls: ASTM E 84 Unadhered

Contact [clientservices@maharam.com](mailto:clientservices@maharam.com) with any questions.