

Flame Certificate
Tek-Wall Drift
399522

maharam

Tek-Wall Drift was tested and met the following flammability requirements:
Walls: ASTM E 84 Adhered flame 15, smoke 20

Contact clientservices@maharam.com with any questions.