

Flame Certificate
Tek-Wall Foil
399601

maharam

Tek-Wall Foil was tested and met the following flammability requirements:

Upholstered Walls: ASTM E 84 Unadhered

Walls: ASTM E 84 Adhered flame 20, smoke 50

Contact clientservices@maharam.com with any questions.