

Flame Certificate  
Tek-Wall Parable  
398650

**maharam**

Tek-Wall Parable was tested and met the following flammability requirements:

Upholstered Walls: ASTM E 84 Unadhered flame 20, smoke 200

Walls: ASTM E 84 Adhered flame 20, smoke 20

Contact [clientservices@maharam.com](mailto:clientservices@maharam.com) with any questions.