Test Number: 247721



PO Box 1948

1503 Murray Ave

Dalton, Georgia 30722-1948 • Phone 706-278-3013 • Fax 706-272-7057 • E-mail: ittslab@dalton.net

TEST REPORT

Customer: Masland Carpets, Inc.

April 9, 2004

Subject: Specimens of the submitted sample were prepared and tested in accordance with

ASTM E 648-03 and/or Federal Test Method 372. NFPA 253

FLOORING RADIANT PANEL TEST

Sample Description

DIVIDEND

Color: L460A Roll #: R270904A

Back: AB

Test Assembly

Mounted on 6mm FRC Board (Using Parabond M4099 Adhesive)

Test Results	Specimen No. 1		Specimen'No. 2		Specimen No. 3	
Critical Radiant Flux	.60	watts/cm²	.46	watts/cm²	48	watts/cm ²
Total Burn Length	33.0	cm	42.0	cm	43 0	cm
Flame Front Out	48.0	minutes	63.0	minutes	64 0	minutes

Average Critical Radiant Flux

.51 watts/cm²

Estimated Standard Deviation

watts/cm²

coefficient of variation

L Kent Suddeth

Executive Vice President