



IES INDOOR REPORT

PHOTOMETRIC FILENAME : 8CR-TL-L20-835-EM10W-XXX-DIM-UNV-OW-CS-XX_ EM MODE ONLY.IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002

[TEST] GEN FROM BALLABS TEST NO. 20687.0

[TESTLAB] BUILDING ACOUSTICS & LIGHTING LABORATORIES, INC

[ISSUEDATE] 3-FEB-2021

[MANUFAC] WILLIAMS INDOOR

[OTHER] H.E. WILLIAMS, INC - CARTHAGE, MO. 64836

[LUMINAIRE] 1 BRIDGELUX V13 LED 8" ROUND SURFACE CYLINDER

[MORE] OPEN SEMI-SPEC SPUN ALUMINUM REFLECTOR (WIDE)

[MORE] ADVANCE #XI025C070V054DSM5 @ 470mA

[LUMCAT] 8CR-TL-L20-835-EM10W-xxx-DIM-UNV-OW-CS-xx EM MODE ONLY

[LAMPCAT] V13 BXRE-35E2000

CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	1046
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	105
Total Luminaire Watts	10
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.26
Spacing Criterion (90-270)	1.26
Spacing Criterion (Diagonal)	0.98
Basic Luminous Shape	Circular
Luminous Length (0-180)	0.48 ft (Diameter)
Luminous Width (90-270)	0.48 ft (Diameter)
Luminous Height	0.00 ft

LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	1937	1937	1937
55	675	675	675
65	141	141	141
75	0	0	0
85	0	0	0

IES INDOOR REPORT

PHOTOMETRIC FILENAME : 8CR-TL-L20-835-EM10W-XXX-DIM-UNV-OW-CS-XX_ EM MODE ONLY.IES

CANDELA TABULATION

	<u>0</u>
0	834.405
5	787.993
10	867.342
15	865.844
20	904.271
25	989.109
30	971.642
35	301.424
40	41.421
45	22.956
50	13.474
55	6.488
60	3.493
65	0.998
70	0.000
75	0.000
80	0.000
85	0.000
90	0.000

IES INDOOR REPORT**PHOTOMETRIC FILENAME : 8CR-TL-L20-835-EM10W-XXX-DIM-UNV-OW-CS-XX_ EM MODE ONLY.IES****ZONAL LUMEN SUMMARY**

Zone	Lumens	%Lamp	%Fixt
0-20	327.31	N.A.	31.30
0-30	774.02	N.A.	74.00
0-40	1018.69	N.A.	97.40
0-60	1044.62	N.A.	99.90
0-80	1045.96	N.A.	100.00
0-90	1045.96	N.A.	100.00
10-90	967.35	N.A.	92.50
20-40	691.38	N.A.	66.10
20-50	710.67	N.A.	67.90
40-70	27.27	N.A.	2.60
60-80	1.34	N.A.	0.10
70-80	0.00	N.A.	0.00
80-90	0.00	N.A.	0.00
90-110	0.00	N.A.	0.00
90-120	0.00	N.A.	0.00
90-130	0.00	N.A.	0.00
90-150	0.00	N.A.	0.00
90-180	0.00	N.A.	0.00
110-180	0.00	N.A.	0.00
0-180	1045.96	N.A.	100.00

Total Luminaire Efficiency = N.A. %

ZONAL LUMEN SUMMARY

Zone	Lumens
0-10	78.61
10-20	248.69
20-30	446.72
30-40	244.67
40-50	19.28
50-60	6.65
60-70	1.34
70-80	0.00
80-90	0.00
90-100	0.00
100-110	0.00
110-120	0.00
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

IES INDOOR REPORT

PHOTOMETRIC FILENAME : 8CR-TL-L20-835-EM10W-XXX-DIM-UNV-OW-CS-XX_ EM MODE ONLY.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	114	111	108	106	111	109	106	104	105	103	101	101	99	98	97	96	95	94
2	108	103	99	96	106	101	98	95	98	95	93	95	93	91	92	90	89	87
3	102	96	91	87	100	95	90	86	92	88	85	90	86	84	87	85	82	81
4	97	90	84	80	95	89	83	79	86	82	79	84	81	78	83	79	77	75
5	92	84	78	74	91	83	77	73	81	76	73	79	75	72	78	74	71	70
6	87	78	72	68	86	78	72	68	76	71	67	75	70	67	73	70	67	65
7	83	74	68	63	82	73	67	63	72	67	63	70	66	62	69	65	62	61
8	79	69	63	59	78	69	63	59	67	62	59	66	62	58	65	61	58	57
9	75	65	59	55	74	65	59	55	64	58	55	63	58	55	62	57	54	53
10	71	61	55	51	70	61	55	51	60	55	51	59	54	51	58	54	51	50

IES INDOOR REPORT

PHOTOMETRIC FILENAME : 8CR-TL-L20-835-EM10W-XXX-DIM-UNV-OW-CS-XX_ EM MODE ONLY.IES

UGR TABLE - CORRECTED

Reflectances

Ceiling Cavity	70	70	50	50	30	70	70	50	50	30
Walls	50	30	50	30	30	50	30	50	30	30
Floor Cavity	20	20	20	20	20	20	20	20	20	20

Room Size UGR Viewed Crosswise

X=2H	Y=2H	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
	3H	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
	4H	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
	6H	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
	8H	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
	12H	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2

UGR Viewed Endwise


4H	2H	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
	3H	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
	4H	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
	6H	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
	8H	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
	12H	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
8H	4H	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
	6H	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
	8H	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
	12H	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
12H	4H	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
	6H	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
	8H	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2

Maximum UGR = 0.2

IES INDOOR REPORT

PHOTOMETRIC FILENAME : 8CR-TL-L20-835-EM10W-XXX-DIM-UNV-OW-CS-XX_ EM MODE ONLY.IES

POLAR GRAPH



Maximum Candela = 989.109 Located At Horizontal Angle = 0, Vertical Angle = 25

1 - Vertical Plane Through Horizontal Angles (90 - 270)

2 - Horizontal Cone Through Vertical Angle (25) (Through Max. Cd.)