

USG Corporation  
550 West Adams Street  
Chicago, IL 60661-3676  
1 800 USG4YOU (874-4968)  
www.usg.com



## Manufacturer's Certificate of Compliance – Low VOC Emissions USG Corporation

USG Corporation certifies the following products have low VOC and formaldehyde emissions per the testing Standard established by the California Department of Health Services:

### **USG SHEETROCK® Brand Firecode® Core Gypsum Panels [Tested]**

IMPERIAL® Brand Gypsum Base Firecode® C Core  
IMPERIAL® Brand Gypsum Base Firecode® Core  
SHEETROCK® Brand Firecode® C Core Gypsum Panels  
SHEETROCK® Brand ULTRACODE® Core Gypsum Panels  
SHEETROCK® Brand Gypsum Liner Panels  
SHEETROCK® Brand Abuse-Resistant Firecode® Core Gypsum Panels  
ROCKLATH® FIRECODE® Core Plaster Base  
SHEETROCK® Brand Gypsum Panels  
SHEETROCK® Brand Sag-Resistant Interior Gypsum Ceiling Board  
SHEETROCK® Brand Flexible Gypsum Panels  
SHEETROCK® Brand Abuse Resistant Gypsum Panels  
SHEETROCK® MH Brand Gypsum Panels (TUF-BASE)  
SHEETROCK® MH Brand Gypsum Base Board  
SHEETROCK® Brand Gypsum Ceiling Base-Sag-Resistant  
SHEETROCK® MH Brand Gypsum Ceiling Board (ULTRA-BASE)

USG certifies the above listed products are Low-Emitting, defined as a concentration for each individual volatile organic compound specified in the *Standard Method for the Testing and Evaluation of Volatile Organic Chemical Emissions from Indoor Sources Using Environmental Chambers, Version 1.1* (CDPH/EHLB/Standard Method V1.1-2010; aka, chamber testing portion of CA Section 01350) and ASTM Standard Guide D5116-06.

The actual test sample as indicated above was manufactured on February 17, 2014 and shipped to Berkeley Analytical as a representative sample. The test results are compliant with VOC emission requirements of the CA Section 01350 Standard as attested in Berkeley Analytical report 059-203-01A-Mar2014. Because USG's manufacturing specifications for ingredients and processes are substantially similar for all the products listed above and for the product actually tested, and because USG has in place a product quality program and VOC testing program, all listed products will meet the VOC emission requirements as defined in the Standard.

Meeting the strictest indoor environmental quality guidelines for zero and low-VOC emissions, is just one way USG is able to help our customers create sustainable spaces. Please visit our website at [usg.com](http://usg.com) to learn more about EcoBlueprint, USG's sustainability initiative and how together we can reduce our overall impact on the environment and construct high-performing, healthy interiors.

Dated: April 11, 2014

A handwritten signature in black ink that reads "Lanita Stevens".

Lanita Stevens  
Manager, Product Stewardship & Sustainability  
USG Corporation



# COMPLIANCE TESTED by berkeley analytical

## VOC Emission Test Certificate

**Product Name:** SHEETROCK® Brand FIRECODE® Core Gypsum Panels

Product Sample Information		Certificate Information	
Manufacturer:	USG Corporation	Certificate No:	140310-01
Manf. Website:	www.usg.com	Certified By:	
CSI Category & No.:	Gypsum Board (09 29 00)		Raja S. Tannous, Laboratory Director
Date Produced:	2/17/2014	Date:	March 10, 2014

**Reference Standard:** California Department of Public Health CDPH/EHLB/Standard Method Version 1.1, 2010  
(Emission testing method for CA Specification 01350)

### Acceptance Criteria and Results Demonstrating Compliance of Product Sample to Referenced Standard:

Exposure Scenario <sup>1</sup>	Individual VOCs of Concern <sup>2</sup>		Formaldehyde <sup>3</sup>		TVOC <sup>4</sup>
	Criterion	Compliant?	Criterion	Compliant?	Range
School Classroom	≤½ Chronic REL	YES	≤9.0 µg/m <sup>3</sup>	YES	≤ 0.5 mg/m <sup>3</sup>
Private Office	≤½ Chronic REL	YES	≤9.0 µg/m <sup>3</sup>	YES	≤ 0.5 mg/m <sup>3</sup>

**Product Coverage<sup>5</sup>:** Not applicable

1. Exposure scenarios & product quantities for classroom & office are defined in Tables 4-2 – 4-5 (CDPH Std. Mtd. V1.1-2010)
2. Maximum allowable concentrations of individual target VOCs are specified in Table 4-1 (*ibid.*)
3. Maximum allowable formaldehyde concentration is ≤9 µg/m<sup>3</sup>, effective Jan 1, 2012; previous limit was ≤16.5 µg/m<sup>3</sup> (*ibid.*)
4. Informative only; predicted TVOC Range in three categories, i.e., ≤0.5 mg/m<sup>3</sup>, >0.5 – 4.9 mg/m<sup>3</sup>, and ≥5.0 mg/m<sup>3</sup>
5. Informative and applicable only to tests of wet-applied products; grams of sample applied per square meter of substrate

### Standards & Codes Recognizing CDPH Standard Method V1.1 (partial list)

- USGBC LEED CI, NC, Schools, Healthcare, 2009
- USGBC LEED Version 4, BD&C, ID&C, 2013
- Collaborative for High Performance Schools (CHPS), National Core Criteria, 2013
- Green Guide for Healthcare, V2.2, 2007
- ANSI/GBI 01-2010, Green Building Assessment Protocol

**Narrative:** USG Corporation selected a sample representative of its SHEETROCK® Brand FIRECODE® Core Gypsum Panels product and submitted it for testing commencing on 2/18/2014. Berkeley Analytical measured and evaluated the emissions of VOCs from this sample following CDPH/EHLB/Standard Method V1.1-2010. The results of the test are presented in Berkeley Analytical report, 059-203-01A-Mar1014.

**Berkeley Analytical** is an independent, third-party laboratory specializing in the analysis of organic chemicals emitted by and contained in building products, finishes, furniture, and consumer products. We are an ISO/IEC 17025 accredited laboratory (IAS, [TL-383](#)); all standards used in performing this test are in Berkeley Analytical's scope of accreditation.

**DISCLAIMER:** THIS CERTIFICATE OF COMPLIANCE AFFIRMS THAT: 1) A SAMPLE OF THE LISTED PRODUCT WAS TESTED ACCORDING TO THE REFERENCED STANDARD; 2) THE MEASURED VOC EMISSIONS FROM THE SAMPLE WERE EVALUATED FOR THE DEFINED EXPOSURE SCENARIO(S); AND 3) THE RESULTS MEET THE ACCEPTANCE CRITERIA OF THE REFERENCED STANDARD(S). BERKELEY ANALYTICAL IS NOT RESPONSIBLE FOR ANY CLAIMS REGARDING A PRODUCT OR PRODUCTS ENTERED INTO COMMERCE THAT MAY BE BASED ON THIS TEST. BERKELEY ANALYTICAL PROVIDES THIS CERTIFICATE OF COMPLIANCE "AS IS" WITHOUT WARRANTY OF ANY KIND, EITHER EXPRESSED OR IMPLIED, INCLUDING BUT NOT LIMITED TO, THE IMPLIED WARRANTIES OF MERCHANTABILITY OR FITNESS FOR ANY PURPOSE.

©2012 Berkeley Analytical, 815 Harbour Way South, Suite 6, Richmond, CA 94804 / 510-236-2325 / [www.berkeleyanalytical.com](http://www.berkeleyanalytical.com)

FC17B.1