Flammability Certificate
3128 Blur

DESIGNTEX

3128 Blur was tested and met the following flammability requirements:

ASTM E84 Adhered Class A
ASTM E84 Unadhered Class A

© 2025 Designtex
800.221.1540
designtex.com
Updated 12.04.25

96-D Allen Boulevard
Farmingdale, New York 11735-5626 USA
Tel. +1 (631) 293-8944 Fax +1 (631) 293-8956
email: govmark.accounting@sgs.com

SGS GOVMARK

Received: 02/01/2019	Completed: 02/11/2019	Letter: 2012	JR	P.O.#:	Test Report #:	3-30694-0-RV
Client's Identification	Style: Blur 3128 with Acrylic Backing. Color Light Grey. Product End Use: Wallcovering.					
Tested For:				Key Test: ASTM E84/ACT RVNC		
				Tel:	Ext:	
				Fax:		

Test Category: Tunnel Test Specifier: ACT LE 2018; V 01/19 PC: ME dl/SM BB/mg

TEST PERFORMED: ASTM E84 - Standard Test Method for Surface Burning Characteristics of Building Materials [LE 2018a; V 9/18] --

As cited by the Association of Contract Textiles (ACT) Voluntary Performance Guidelines (August 2018)

APPROXIMATE THICKNESS OF SPECIMEN (as measured by SGS Govmark): 0.034"

SPECIMEN WEIGHT (to include substrate when applicable):

Prior to Conditioning: 108.2 lbs.

Stabilized Weight (taken twice within 24 hours): 107.5 lbs.

PRODUCT CATEGORY:

[x] Textile Type Product

[ ] Vinyl Type Product

[ ] Other than Textile Type or Vinyl Type Product: _____

BRIEF DESCRIPTION OF TEST: This test method is used to determine the relative burning behavior of a material under defined test conditions. The test is performed in a 25 ft. long tunnel/duct-like apparatus and is often referred to as the "tunnel test". The test contemplates a calibration where Red Oak burns to the 24 ft. mark in 5.5 minutes ± 15 seconds. During the actual test, a 24 ft. long x 23" wide specimen rests horizontally in a ceiling configuration inside the test chamber facing downward and toward two upward oriented burners. A furnace lid that rests in a water trough seals the chamber tight. A cement board placed on the backside of each specimen assembly protects the furnace lid during the test. The near face of the specimen is subjected to a 4.5 ft. flame insult of approximately 88 kW for ten minutes. The time and distance of the spread of flame along the length of the specimen and the smoke developed as read by the photometric system are all recorded. The Flame Spread and Smoke Developed are reported as an Index.

-- See Page 3 for "Results" --

SGS GOVMARK

96-D Allen Boulevard
Farmingdale, New York 11735-5626 USA
Tel. +1 (631) 293-8944 Fax +1 (631) 293-8956
email: govmark.accounting@sgs.com

Received: 02/01/2019	Completed: 02/11/2019	Letter: 2012	JR	P.O.#:	Test Report #:	3-30694-0-RV
Client's Identification	Style: Blur 3128 with Acrylic Backing. Color Light Grey. Product End Use: Wallcovering.					

Tested For: **Key Test:** ASTM E84/ACT RVNC

Tel: **Ext:**
Fax:

SPECIMEN MOUNTING:

[ ] Self-supporting: The test specimen was rigid enough to be self-supporting when placed into test position. No additional support was required.

[ ] Adhered to IRC: The test specimen was bonded to 1/4" Inorganic Reinforced Cement (IRC) boards.

[x] Adhered to Gypsum: The test specimen was adhered to 5/8" thick Type X gypsum board.

[ ] Unadhered: The specimen was not adhered to any substrate. Instead, it was laid over a 2" hexagonal wire mesh screen and 1/4" rods.

[ ] Other: _____

SPECIMEN LENGTH: The 24 ft. length was comprised of:

[ ] Continuous unbroken 24 ft. length
[x] Sections: [x] Three 8 ft. sections butted end to end
[ ] Three 8 ft. sections positively joined
[ ] Other: _____

ADHESIVE (applied by Govmark: [ ] No
[x] Yes (specify): Roman-Pro 880

OBSERVATIONS: [ ] No unusual observations
[ ] Delamination
[ ] Sagging
[ ] Shrinkage
[ ] Fallout (specimen displacement from ceiling mount)
[x] Other: Minor burning and dripping to oven floor

REMARKS: [x] None
[ ] Other: _____

SGS GOVMARK

96-D Allen Boulevard
Farmingdale, New York 11735-5626 USA
Tel. +1 (631) 293-8944 Fax +1 (631) 293-8956
email: govmark.accounting@sgs.com

Received: 02/01/2019	Completed: 02/11/2019	Letter: 2012	JR	P.O.#:	Test Report #:	3-30694-0-RV
Client's Identification	Style: Blur 3128 with Acrylic Backing. Color Light Grey. Product End Use: Wallcovering.					

Tested For: **Key Test:** ASTM E84/ACT RVNC

Tel: **Ext:**
Fax:

RESULTS: Flame Spread Index: 25
Smoke Developed: 65

ROUNDING: Flame Spread Index value has been rounded to the nearest multiple of 5.
Smoke Developed value has been rounded to:

Raw Data	Rounded
Less than 200	Nearest multiple of 5
200 or more	Nearest multiple of 50

ACCEPTANCE CRITERIA (as cited by ACT):

	Flame Spread Index	Smoke Developed
Class A	0 -25	450 or less

NOTE: Class A is also known as Class 1 and may be so specified in some Codes.

CONCLUSION: Based on the reported Results and cited Acceptance Criteria, the item tested:

[x] Complies; [ ] Does not comply

DATA SUMMARY: Time to Ignition (minutes:seconds): 00:18
Maximum Flame Spread "Distance" (feet): 5.8
Maximum Flame Spread "Time" (seconds): 106

CODE CLASSIFICATION: Based on the reported Results and cited Code Classifcation System, the item tested is assigned a:

[x] Class I or A rating
[ ] Class II or B rating
[ ] Class III or C rating
[ ] Fails to achieve a minimum classification thereby rendering the product unsuitable in terms of code requirement
[ ] Based on product performance*, ASTM E84 is not a suitable test method for the material.

* Severe melt, drip, delamination or other behavior that destroys the continuity of the flame front such that a valid flame spread is unobtainable (See "Remarks" on Page 2 of 4.)

-- See Page 4 for "Code Classification System" --

96-D Allen Boulevard
Farmingdale, New York 11735-5626 USA
Tel. +1 (631) 293-8944 Fax +1 (631) 293-8956
email: govmark.accounting@sgs.com

SGS GOVMARK

Received: 02/01/2019	Completed: 02/11/2019	Letter: 2012	JR	P.O.#:	Test Report #:	3-30694-0-RV
Client's Identification	Style: Blur 3128 with Acrylic Backing. Color Light Grey. Product End Use: Wallcovering.					
Tested For:				Key Test: ASTM E84/ACT RVNC		
				Tel:	Ext:	
				Fax:		

CODE CLASSIFICATION SYSTEM:

	Flame Spread Index	Smoke Developed
Class I or A:	0 - 25	450 or less
Class II or B:	26 - 75	450 or less
Class III or C:	76 - 200	450 or less

LIMITATIONS OF THE ASTM E84 CLASSIFICATION SCHEME: Most building codes will accept the ASTM E84 classifications when the interior finish product is used in a sprinklered area. Certain local authorities such as NYC have more stringent requirements, i.e. Smoke Developed ranges from a maximum 25 to 100.

If the interior finish product is a textile or vinyl wall covering used in a non-sprinklered area, the NFPA 265 room corner fire test applies.

Certain products which give off excessive heat such as but not limited to cellular plastics, cellular foam (either with or without coverings as applicable), polypropylene, and high density polyethylene should be tested by NFPA 286 - Standard Methods of Fire Tests for Evaluating Contribution of Wall and Ceiling Interior Finish to Room Fire Growth. In Govmark's opinion, the codes require NFPA 286 for such products, even in sprinklered areas.

CERTIFICATION: I certify that the reported results were obtained after testing specimens in accordance with the procedures and equipment specified above.

RV.04.08.20 /gb

AUTHORIZED SIGNATURE
SGS GOVMARK
/gb

Test Engineer: Jimmy Rosinsky

Phyllis Pettit

APR 0 9 2020

Enclosure: Graphs

The results contained in this report relate only to item(s) tested. The test report shall not be reproduced, except in full, without written approval from Govmark.

SGS GOVMARK

Program: ASTM E84 (Version 1.61)

Test Method	: ASTM E84
Test Report #	: 3-30694-0-R -RV
Date	: 2/11/2019
Client	: Designtex
Operator	: Jimmy Rosinsky
Details of Preparation	: The test specimen was adhered to 5/8" thick Type X gypsum board using Roman 880 glue. The 24 ft. length was comprised of three 8 ft. sections butted end to end.
Observations	: Minor burning drip to oven floor.

Area Under Flame Curve (ft min)	: 52.50
Raw Flame Spread Index (ft min)	: 27.04
Rounded Flame Spread Index (ft min)	: **25**
Ignition Time	: **00:18 mm:ss**
Area Under Smoke Curve (%A min)	: 47.46
Raw Smoke-Developed Index	: 64.37
Rounded Smoke-Developed Index	: **65**
Total Gas Flow(L)	: 1367.5
Total Gas Flow(ft^3)	: 48.3
Maximum Flame Front Achieved(ft)	: 5.8 (@106s)



SGS GOVMARK

Program: ASTM E84 (Version 1.61)

Test Method : ASTM E84
Test Report # : 3-30694-0-R -RV



SGS

Tested For:		**Phone:**		**Received:**	3/22/2023
	Designtex	**Fax:**		**Completed:**	3/29/2023
	357 County Avenue	**Mobile:**		**Code:**	Y
	Secaucus, NJ 07094	**PO#:**		**Test Report:**	3-50941-0
	USA	**Email:**			

Key Test: ASTM E84/ACT 630

Client's Identification:

Product Description: Blur 3128.

Test Category: Tunnel Test Specifier: ACT LE 2023; V 3/23 BG PC: ME

TEST PERFORMED: ASTM E84 - Standard Test Method for Surface Burning Characteristics of Building Materials [LE 2018a; V 9/18] --

As cited by the Association of Contract Textiles (ACT) Voluntary Performance Guidelines (December 2021)

APPROXIMATE THICKNESS OF SPECIMEN (as measured by SGS North America): 0.013"

SPECIMEN WEIGHT (to include substrate when applicable):

Prior to Conditioning: 2.0 lbs.

Stabilized Weight (taken twice within 24 hours): 2.0 lbs.

PRODUCT CATEGORY:

☒ Textile Type Product
☐ Vinyl Type Product
☐ Other than Textile Type or Vinyl Type Product: _____

BRIEF DESCRIPTION OF TEST: This test method is used to determine the relative burning behavior of a material under defined test conditions. The test is performed in a 25 ft. long tunnel/duct-like apparatus and is often referred to as the "tunnel test". The test contemplates a calibration where Red Oak burns to the 24 ft. mark in 5.5 minutes ± 15 seconds. During the actual test, a 24 ft. long x 23" wide specimen rests horizontally in a ceiling configuration inside the test chamber facing downward and toward two upward oriented burners. A furnace lid that rests in a water trough seals the chamber tight. A cement board placed on the backside of each specimen assembly protects the furnace lid during the test. The near face of the specimen is subjected to a 4.5 ft. flame insult of approximately 88 kW for ten minutes. The time and distance of the spread of flame along the length of the specimen and the smoke developed as read by the photometric system are all recorded. The Flame Spread and Smoke Developed are reported as an Index.

The results contained in this report relate only to the item(s) tested. The test report shall not be reproduced except in full, without written approval from SGS North America.

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at http://www.sgs.com/en/Terms-and-Conditions.aspx and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at http://www.sgs.com/en/Terms-and-Conditions/terms-e-document.aspx. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for a maximum of 45 days only.

96 Allen Boulevard Suite D, Farmingdale, NY 11735 USA • Phone: (631) 293-8944 • Email: govmark.test.reports@sgs.com

SGS

Tested For:		**Phone:**		**Received:**	3/22/2023
	Designtex	**Fax:**		**Completed:**	3/29/2023
	357 County Avenue	**Mobile:**		**Code:**	Y
	Secaucus, NJ 07094	**PO#:**		**Test Report:**	3-50941-0
	USA	**Email:**			

Key Test: ASTM E84/ACT 630

SPECIMEN MOUNTING:

☐ Self-supporting: The test specimen was rigid enough to be self-supporting when placed into test position. No additional support was required.

☐ Adhered to IRC: The test specimen was bonded to ¼" Inorganic Reinforced Cement (IRC) boards.

☐ Adhered to Gypsum: The test specimen was adhered to $^5/_8$" thick Type X gypsum board.

☒ Unadhered: The specimen was not adhered to any substrate. Instead, it was laid over a 2" hexagonal wire mesh screen and ¼" rods.

☐ Other: _____

SPECIMEN LENGTH: The 24 ft. length was comprised of:

☐ Continuous unbroken 24 ft. length
☒ Sections: ☒ Three 8 ft. sections butted end to end
☐ Three 8 ft. sections positively joined
☐ Other: _____

ADHESIVE (applied by SGS North America): ☒ No
☐ Yes (specify):_____

OBSERVATIONS: ☐ No unusual observations
☒ Burning Drips to Floor further qualified as: ☒ Minor; ☐ Moderate; ☐ Major
☐ Delamination
☐ Sagging
☐ Shrinkage
☐ Fallout (specimen displacement from ceiling mount)
☐ Other: _____

REMARKS: ☒ None
☐ Other: _____

The results contained in this report relate only to the item(s) tested. The test report shall not be reproduced except in full, without written approval from SGS North America.

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at http://www.sgs.com/en/Terms-and-Conditions.aspx and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at http://www.sgs.com/en/Terms-and-Conditions/terms-e-document.aspx. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for a maximum of 45 days only.

96 Allen Boulevard Suite D, Farmingdale, NY 11735 USA • Phone: (631) 293-8944 • Email: govmark.test.reports@sgs.com

SGS

Tested For:		Phone:		Received:	3/22/2023
	Designtex	Fax:		Completed:	3/29/2023
	357 County Avenue	Mobile:		Code:	Y
	Secaucus, NJ 07094	PO#:		Test Report:	3-50941-0
	USA	Email:			

Key Test: ASTM E84/ACT 630

RESULTS: Flame Spread Index: 5
Smoke Developed: 60

ROUNDING: Flame Spread Index value has been rounded to the nearest multiple of 5.
Smoke Developed value has been rounded to:

Raw Data	Rounded
Less than 200	Nearest multiple of 5
200 or more	Nearest multiple of 50

ACCEPTANCE CRITERIA (as cited by ACT):

	Flame Spread Index	Smoke Developed
Class A	0 - 25	450 or less

NOTE: Class A is also known as Class 1 and may be so specified in some Codes.

CONCLUSION: Based on the reported Results and cited Acceptance Criteria, the item tested:

☒ Complies ☐ Does not comply

DATA SUMMARY:

Time to Ignition (minutes:seconds): 00:11
Maximum Flame Spread "Distance" (feet): 1.1
Maximum Flame Spread "Time" (seconds): 24

CODE CLASSIFICATION: Based on the reported Results and cited Code Classification System, the item tested is assigned a:

☒ Class I or A rating
☐ Class II or B rating
☐ Class III or C rating
☐ Fails to achieve a minimum classification thereby rendering the product unsuitable in terms of code requirement.
☐ Based on product performance*, ASTM E84 is not a suitable test method for the material.

* Severe melt, drip, delamination, or other behavior that destroys the continuity of the flame front such that a valid flame spread is unobtainable (See "Remarks" on Page 2 of 4.)

The results contained in this report relate only to the item(s) tested. The test report shall not be reproduced except in full, without written approval from SGS North America.

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at http://www.sgs.com/en/Terms-and-Conditions.aspx and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at http://www.sgs.com/en/Terms-and-Conditions/terms-e-document.aspx. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for a maximum of 45 days only.

96 Allen Boulevard Suite D, Farmingdale, NY 11735 USA • Phone: (631) 293-8944 • Email: govmark.test.reports@sgs.com

DocuSign Envelope ID: F22D2C87-F6AF-454B-97CF-2727B4785695

SGS

Tested For:		**Phone:**		**Received:**	3/22/2023
	Designtex	**Fax:**		**Completed:**	3/29/2023
	357 County Avenue	**Mobile:**		**Code:**	Y
	Secaucus, NJ 07094	**PO#:**		**Test Report:**	3-50941-0
	USA	**Email:**			

Key Test: ASTM E84/ACT 630

CODE CLASSIFICATION SYSTEM:

	Flame Spread Index	Smoke Developed
Class I or A:	0 - 25	450 or less
Class II or B:	26 - 75	450 or less
Class III or C:	76 - 200	450 or less

LIMITATIONS OF THE ASTM E84 CLASSIFICATION SCHEME: Most building codes will accept the ASTM E84 classifications when the interior finish product is used in a sprinklered area. Certain local authorities such as NYC have more stringent requirements, i.e. Smoke Developed ranges from a maximum 25 to 100.

If the interior finish product is a textile or vinyl wall covering used in a non-sprinklered area, the NFPA 265 room corner fire test applies.

Certain products which give off excessive heat such as but not limited to cellular plastics, cellular foam (either with or without coverings as applicable), polypropylene, and high density polyethylene should be tested by NFPA 286 - Standard Methods of Fire Tests for Evaluating Contribution of Wall and Ceiling Interior Finish to Room Fire Growth. In SGS North America's opinion, the codes require NFPA 286 for such products, even in sprinklered areas.

CERTIFICATION: I certify that the reported results were obtained after testing specimens in accordance with the procedures and equipment specified above.

DocuSigned by:
Bobby Brown
B50EB94D593C454...

3/31/2023

AUTHORIZED SIGNATURE
SGS NORTH AMERICA
/jab /dv

Test Engineer: Chris Gangi

DS
BB

Enclosure: Graphs

The results contained in this report relate only to the item(s) tested. The test report shall not be reproduced except in full, without written approval from SGS North America.

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at http://www.sgs.com/en/Terms-and-Conditions.aspx and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at http://www.sgs.com/en/Terms-and-Conditions/terms-e-document.aspx. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for a maximum of 45 days only.

96 Allen Boulevard Suite D, Farmingdale, NY 11735 USA • Phone: (631) 293-8944 • Email: govmark.test.reports@sgs.com

DocuSign Envelope ID: F22D2C87-F6AF-454B-97CF-2727B4785695

Program: Steiner Tunnel (Version 1.0.2.0)

Test Method	:	ASTM E84
Report #	:	3-50941-0-Y
Test Date	:	3/29/2023
Client	:	Desigtex
Operator	:	Chris Gangi
Details of Preparation	:	The specimen was not adhered to any substrate. Instead, it was laid over a 2" hexagonal wire mesh screen and 1/4" rods. The 24ft. length was comprised of three 8ft. sections butted end to end.
Observations	:	Minor burning drips onto tunnel floor resulting in small pocket of fire on floor.

Results

Area Under Flame Curve (ft min)	:	10.73
Raw Flame Spread Index	:	5.53
Ignition Time (mm:ss)	:	00:11
Area Under Smoke Curve (%A min)	:	47.01
Raw Smoke Developed Index	:	59.57
Total Gas Flow (ft^3)	:	56.3
Maximum Flame Front Achieved (ft)	:	1.1 @ 24s
Flame Spread Index	:	**5**
Smoke Developed Index	:	**60**
Material Classification	:	**A**

CERTIFICATION : I certify that the above results were obtained after testing the specimens in accordance with the procedures and equipment specified by ASTM E84

Chris Gangi

AUTHORIZED SIGNATURE

DocuSign Envelope ID: F22D2C87-F6AF-454B-97CF-2727B4785695

Program: Steiner Tunnel (Version 1.0.2.0)

Test Method : ASTM E84
Test Report # : 3-50941-0-Y